


## **Ekonomska skola Vukovar**

Date: 14.09.2020  
Operator:



Operator  
Telephone  
Fax e-  
Mail

### Vanjski prostor\_prolaz između škole i dvorane / Planning data






Light loss factor: 0.80, ULR (Upward Light Ratio): 0.5%


Scale 1:535

#### Luminaire Parts List

No.	Pieces	Designation (Correction Factor)	□ (Luminaire) [lm]	□ (Lamps) [lm]	P [W]
1	8	surface mounted, with microwave motion sensor (1.000)	4329	4330	35.0
Total: 34635			Total: 34640	280.0	

### Vanjski prostor\_prolaz između škole i dvorane / Luminaire parts list


8 Pieces  See our luminaire catalog  
surface mounted, with microwave motion sensor for an image of the Article No.:  
 luminaire.  
Luminous flux (Luminaire): 4329 lm  
Luminous flux (Lamps): 4330 lm  
Luminaire Wattage: 35.0 W  
Luminaire classification according to CIE: 86  
CIE flux code: 40 70 90 86 100  
Fitting  (Correction Factor 1.000).





Operator  
Telephone  
Fax e-  
Mail

### Vanjski prostor\_prolaz između škole i dvorane / Luminaires (layout plan)



Scale 1 : 535

### Luminaire Parts List

No.	Pieces	Designation
1	8	interior, surface mounted, with microwave motion sensor

### Vanjski prostor\_prolaz između škole i dvorane / Calculation surfaces (results overview)



Scale 1 : 535

### Calculation Surface List

No.	Designation	Type	Grid	$E_{av}$ [lx]	$E_{min}$ [lx]	$E_{max}$ [lx]	$u_0$	$E_{min} / E_{max}$
1	Prolaz između škole i dvorane	perpendicular	128 x 32	26	8.73	47	0.338	0.184